



SECTION A - A

Note:

The casing pipe shall be elastic fusion welded steel pipe conforming to the requirements of the ASTM specifications A-139 Grade "B" (No Hydro), and shall have a minimum yield strength of 35,000 P.S.I. Joints in the casing pipe shall be butt welded with a weld size at least equal to the thickness of the pipe.

The pipe shall be protected against corrosion by a protective coating on the outside of the pipe consisting of black bituminous base coating or an approved equal.

REV No.	DATE	BY	DESCRIPTION
1	2/18/04	DAH	General Revisions - Re-Issue
CITY OF WESTLAKE, OHIO DEPARTMENT OF ENGINEERING			
BORING DETAIL BLANK			
SCALE: AS NOTED			8a
DATE:		DRWN BY:	